

MONTEREY BAY UNIFIED AIR POLLUTION CONTROL DISTRICT
Serving Monterey, San Benito, and Santa Cruz Counties
24580 Silver Cloud Court ♦ Monterey, CA 93940 ♦ (831)647-9411 / FAX (831)647-8501

ANNUAL INSPECTION CHECKLIST – “PHIL-TITE BALANCE SYSTEM - <100K GAL/YR”

STATION NAME (dba): _____ PERMIT NO: _____ MONTH/YEAR _____ 20_____		
ACTIVITY	INITIALS	DATE
PERFORM ANNUALLY (Minimum) - Initials of individual who performed the activity.		
Spill Containment Dust Cap – Seal in place and in good condition?		
Spill Containment Boxes - Free of all liquid and debris?		
Drop Tubes – “Leak Test of Drop Tube Overfill Device and Spill Container Drain Valve Test” performed in accordance with CARB Procedure TP 201.D?		
Phase I Vapor Recovery System – “Static Pressure Performance Test” performed in accordance with CARB Procedure TP 201.3?		
Rotatable Phase I Adaptors – “Static Torque of Rotatable Phase I Adaptors Test” performed in accordance with CARB procedure TP 201.1B?		
Drain Valves in spill containment boxes - Open and close while pulling on the handle/chain?		
Tank Caps - Gaskets in place, no cracks, and locked tightly in place?		
Pressure/Vacuum Vent Valve(s) – in place, cleaned, not damaged, and with screen in place?		
Phil-Tite Vapor Side Debris Basket – in place and in good condition?		
Phil-Tite Vapor Side Hand Pump – Available and in good condition?		

