MONTEREY BAY
Unified Air Pollution Control District
serving Monterey, San Benito, and Santa Cruz counties

24580 Silver Cloud Court • Monterey, California 93940 • 831/647-9411 • FAX 831/647-8501

APCD USE ONLY

LIQUID REMOVAL TEST

(Liquid Removal Test is Required if the Volume of Liquid drained equals or exceeds 25 ml)

TP 201.6C

☐ Renewal Testing ☐ Engineering Startup/Evaluation

SOURCE INFORMATION			TEST COMPANY INFORMATION		
Facility (DBA)/Site Address:		Facility Representative/Title:	Company Name/Address		Company Representative
Print Name		Print Name	Print Name		Print Name
Print DBA (if applicable)		Title	Street Address		Signature
Street Address		Phase I System: Executive Order #:	City	Zip	Phone No.
City	Zip	Phone No.	Date of Test		ICC Cert. No.
District Test Witness:		☐ P/O ☐ A/C Number:			

Hose Exhibit #: (check box) ☐8c ☐9c ☐10 ☐11	**[A]** Grade points not tested due to low flow rate (<5.0 gpm):	Total number of grade points LR tested: (excluding boxes [A], [B],&[C])
Total grade points on site: (Number of nozzles x fuel grades per nozzle)	**[B]** Grade points not tested due to high flowrate (>10.0 gpm):	# of grade points LR tested that passed:
	[C] Grade points not tested for any reason (eg. Defects):	# of grade points LR tested that failed:

GENERAL INFORMATION		PRE-TEST	RUN TEST (For those Hoses with less than 25 milliliters drained, no further testing is required)						VR	Pass/Fail
Disp. # & Fuel Grade	**Make & Model of Hose**	**Volume Drained from Hose (mL)**	**(I) Volume Poured Into Hose (150 - 175 mL)**	**(G) Gasoline Dispensed (7.5+/-0.5 Gal)**	**(T) Time to Dispense (Seconds)**	**60(G)÷(T) = Dispensing Rate (GPM)**	**(F) Liquid Gasoline Remaining (mL)**	**(W) Liquid Gas Lost With No Dispensing (mL)**	**((I-W-F) ÷ G) Removal Rate (mL/gallon)**	**VR must Be 5.0 or greater to Pass**

LIQUID REMOVAL TEST
TP 201.6C

GENERAL INFORMATION		PRE-TEST	RUN TEST (For those Hoses with less than 25 milliliters drained, no further testing is required)						VR	Pass/Fail
Disp. # & Fuel Grade	**Make & Model of Hose**	**Volume Drained from Hose (mL)**	**(I) Volume Poured Into Hose (150 - 175 mL)**	**(G) Gasoline Dispensed (7.5+/-0.5 Gal)**	**(T) Time to Dispense (Seconds)**	**60(G)÷(T) = Dispensing Rate (GPM)**	**(F) Liquid Gasoline Remaining (mL)**	**(W) Liquid Gas Lost With No Dispensing (mL)**	**((I-W-F) ÷ G) Removal Rate (mL/gallon)**	**VR must Be 5.0 or greater to Pass**