



**2.5 INCH WC FOR 20 MINUTES STATIC PRESSURE PERFORMANCE TEST  
 PILOT LIGHT AND MAIN BURNER VERIFICATION TEST**

ARB EO G-70-139, HIRT VCS 200

Renewal Testing

Engineering Evaluation

SOURCE INFORMATION			TEST COMPANY INFORMATION		
Facility (DBA)/Site Address: Print Name & DBA		Facility Representative/Title: Print Name	Company Name/Address Print Name		Company Representative Print Name
Street Address		Title	Street Address		Signature
City	Zip	Phone No.	City	Zip	Phone No.
District Test Witness:		<input type="checkbox"/> P/O Number:	<input type="checkbox"/> A/C	Date of Test:	ICC Cert. No:

PILOT LIGHT & MAIN BURNER	
<b>HIRT Check List</b> (Check Y or N)	Number of Nozzles Affected:
Is power light on <input type="checkbox"/> Y <input type="checkbox"/> N	Vapor Manifold Location :
Does vacuum light come on <input type="checkbox"/> Y <input type="checkbox"/> N	Date & Time of Most Recent Delivery:
Pilot burner operating properly <input type="checkbox"/> Y <input type="checkbox"/> N	Pressure Measuring Device Type:
Main burner operating properly <input type="checkbox"/> Y <input type="checkbox"/> N	Device Calibration Date:
Vacuum turbine operates properly <input type="checkbox"/> Y <input type="checkbox"/> N	

Tank Number:	1	2	3	4
1. Product Grade				
2. Actual Tank Capacity, gallons				
3. Gasoline Volume				
4. Initial Pressure (2.5 inches H <sub>2</sub> O)				
5. Final Pressure After 20 Minutes, inches H <sub>2</sub> O	2.5	2.5	2.5	2.5
6. Required Final Pressure, inches H <sub>2</sub> O				
7. Pressure Decay Test Results	<b>P / F</b>	<b>P / F</b>	<b>P / F</b>	<b>P / F</b>